



400-1500 l
Volumes

6 bar
95°C
Working pressure tank

10 bar
95°C
Робочий тиск в теплообміннику



VTN-2

- H Hot water
- h1 Cold water, drainage
- h4 Hot water outlet
- h5-h6 Pipes supply and return (TO1-lower heat exchanger)
- h9 Recirculation
- h10-h13 Connecting the control-adjusting and measuring fixtures
- h14 Flange, Ø115mm

V _{tank} , l	Dimensions, mm				S _{TO1} , m ²	V _{TO1} , l	Mounting dimensions, mm									
	H	ØD1	ØD	Ød			h1	h4	h5	h6	h9	h10	h11	h12	h13	h14
400	1705	800	600	450	1,48	11	75	1381	821	181	1031	631	831	931	1431	481
	½"						1"			¾"						
500	1955	800	600	450	1,84	14	75	1631	953	181	1231	681	956	1056	1681	481
	½"						1"			¾"						
750	2025	950	750	600	2,42	18	75	1673	995	223	1273	723	998	1098	1723	523
	½"						1¼"	1"	1"	¾"						
1000	2060	1050	850	700	3,00	29	75	1690	990	240	1290	740	1015	1115	1740	540
	½"						1¼"			1"	¾"					
1500	2200	1200	1000	850	4,10	37	75	1771	1121	321	1371	821	1096	1196	1821	621
	½"						1½"	1¼"		¾"						